Colorado Springs Fire Department

Division of the Fire Marshal Inspection Checklist LP-Gas Exchange/Storage





Disclaimer

CSFD checklists are **not** intended to be all inclusive or stand-alone submittal documents. The items listed include the minimum technical information required to conduct an initial plan review. Please call-out and provide code study for any deviations/exceptions to prescriptive code. The current Fire Code is the 2021 International Fire Code (IFC) with local amendments.

Congratulations, your permit has been approved and you are on your way to getting your project completed. The next step is passing the inspection. To help you prepare, please review the following checklist and make sure you are ready **BEFORE** you call for your final inspection.

Plan review comments MUST be available during the inspection or it is an automatic failure/fee and inspection must be re-scheduled.

Approved Site Plans

Does the site installation match the submitted and approved plans? (Location/distance from exits/distance from lot lines)	Yes	No
2. Are the required NFPA placards the correct size & posted according to plans?	Yes	No □
3. Is vehicle protection in place according to plans?	Yes	No
4. Is no smoking sign posted?	Yes	No
5. Is emergency contact sign posted within 10 ft of storage cabinet?	Yes	No 🗆

Miscellaneous

Is the cage/cabinet secured against unauthorized access?	Yes	No
2. Is the storage cabinet ventilated?	Yes	No
3. Is there a sign on the door posted ""DO NOT BRING LP-GAS CYLINDERS INTO THE BUILDING"?	Yes	No
4. Are weeds, grass, brush, trash and other combustible materials a minimum of 10 ft from tanks or containers?	Yes	No
5. Are extinguishers present within the required distance?	Yes	No
6. Are extinguishers the correct size and quantity?	Yes	No